

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Plastic**

Material type: Soft PVC foil
Article description: Image Perfect IP 2585 FloorApp
Dimensions: as specified: variable;
test sample: 1000 x 500 x 33.3 [mm]
(carrier plate: Alu-Dibond plate)
Colour: white (unprinted)
Surface: even, fine rough with hexagonal embossed surface,
matt

Manufacturer/
supplier: Spandex Group
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Client: Spandex Group
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Certificate No.: 90192001.001e
(tested under: 89552001.001)

Test date: 19.02.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method
- Ramp test"
The sample flooring was delivered in a surface condition ready for testing.

Test result: Average total acceptance angle: **8,9°**


Assessment: **Classification group of anti-slip property: R 9**

SÄUREFLIESNER-VEREINIGUNG E. V.

Institut für Wand- und Bodenbeläge

Managing Director

Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 07.04.2020
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBT nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

