

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Plastics**

Kind of material: soft PVC foil
Article description: ImagePerfect IP 2595
Dimensions: according to specification: variable;
test specimen: 1000 x 500 x 0,14 [mm]
Colour: white
Surface: even, fine rough, matt
Producer/supplier: SPANDEX GROUP
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Client: Spandex AG
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Certificate No.: 90612001.001e

Test date: 19.05.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method
- Ramp test"

The sample covering was delivered in a surface condition ready
for testing.

Test result: Average total acceptance angle: **9,0°**


Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.

Institut für Wand- und Bodenbeläge

Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 14.08.2020
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -
SÄUREFLIESNER-VEREINIGUNG E. V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn. Nr. NDS 30 anerkannt und nach EU BauPVO zertifizierte Stelle Nr. 1212

