

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Plastics**

Kind of material: Soft self-adhesive PVC film  
Article number: IP 2830-201  
Dimensions: variable by arrangement; 1000 x 500 x 0,22 (mm)  
Colour: transparent  
Surface: fine-grained structure  
Hersteller/Lieferer: Spandex Group  
Aegertweg 6  
8305 Dietlikon  
SCHWEIZ

Client: Spandex AG  
Aegertweg 4  
8305 Dietlikon  
SCHWEIZ

Certificate No.: 92112001.001e

Test date: 06.11.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method  
- Ramp test"  
The sample flooring was delivered in a testable surface condition.

Test result: Average total acceptance angle: **8,5°**

Assessment: **Classification group of anti-slip property: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 17.11.2020  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E. V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

