

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **Plastics**

Kind of material: soft PVC foil
Article description: IP 2830-220 Sandstone
Dimensions: according to specification: variable;
test specimen: 1000 x 500 x 0,10 [mm]
Colour: transparent
Surface: even, fin rough, matt
Hersteller/Lieferer: SPANDEX GROUP
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Client: Spandex AG
Aegertweg 4
8305 Dietlikon
SWITZERLAND

Certificate No.: 95522101.001e
(tested under 90612002.001e)

Test date: 19.05.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method
- Ramp test"
The sample covering was delivered in a surface condition ready
for testing.

Test result: Average total acceptance angle: **8,4°**

Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 20.10.2021
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIRT nach I BO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

